

## TEST REPORT

No. : XMIN2510002430CM04\_EN

Date : 2025-11-03

Page: 1 of 3



CUSTOMER NAME: QINGDAO CSP INDUSTRY AND TRADE CO.,LTD  
 ADDRESS: WEST OF CHENJIABOZI VILLAGE ,JIAOBEI STREET ,JIAZOHOU  
 CITY,QINGDAO CITY,SHANDONG PROVINCE CHINA

Sample Name : Rubber tile

Above information and sample(s) was/were submitted and confirmed by the client. SGS, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

\*\*\*\*\*

SGS Ref. No. : QDIN2510001999PL04  
 Date of Receipt : 2025-10-21  
 Testing Period : 2025-10-21 ~ 2025-10-27  
 Test result(s) : For further details, please refer to the following page(s)  
 (Unless otherwise stated the results shown in this test report refer only to the sample(s) tested)

Signed for  
 SGS-CSTC Standards Technical  
 Services Co.,Ltd. Xiamen Branch.

Bryan Hong  
 Authorized signatory



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: [CN.Doccheck@sgs.com](mailto:CN.Doccheck@sgs.com)

No.31 Xianghong Road, Xiang'an Torch Industrial Zone, Xiamen, Fujian Province, China 361101  
 中国·福建·厦门·火炬(翔安)产业区翔虹路31号 邮编: 361101

t (86-592) 5765857 www.sgsgroup.com.cn  
 t (86-592) 5765857 sgs.china@sgs.com

## TEST REPORT

No. : XMIN2510002430CM04\_EN


Date : 2025-11-03

Page: 2 of 3

### Summary of Results:

No.	Test Item	Test Method	Result
1	Wet Pendulum Test	AS 4586-2013 Amdt 1-2017 Appendix A	SRV "wet": 26 Class: P2

### Original Sample Photo:



## TEST REPORT

No. : XMIN2510002430CM04\_EN

Date : 2025-11-03

Page: 3 of 3

### 1. Test Item: Wet Pendulum Test

Sample Description: See photo

Test Method: AS 4586-2013 Amdt 1-2017 Appendix A

Test Condition:

Specimen: 200mm×150mm, 6pcs

Type of Slider: slider 96 (4S rubber)

Test surface: see photo

Test direction: long side direction

Test Result:

Specimen No.	1	2	3	4	5	6
Mean of British Pendulum Number (for each test surface)	30	25	25	25	25	25
Slip resistance value (SRV "wet")	26					
Class	P2					

Classification of pedestrian surface materials according to the wet pendulum test:

Class	Pendulum SRV (slider 96)
P5	>54
P4	45-54
P3	35-44
P2	25-34
P1	12-24
P0	<12

Note: This test report is an additional version of the original report No.: XMIN2510002430CM01\_EN dated:2025-11-03. The customer name and address have been modified, and the original report is valid.

\*\*\*\*\*End of report\*\*\*\*\*



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.31 Xianghong Road, Xiang'an Torch Industrial Zone, Xiamen, Fujian Province, China 361101  
中国·福建·厦门·火炬(翔安)产业区翔虹路31号 邮编: 361101

t (86-592) 5765857 www.sgsgroup.com.cn  
t (86-592) 5765857 sgs.china@sgs.com